



July 17, 2025

Via Email: [cao@lanigan.ca](mailto:cao@lanigan.ca)

Town of Lanigan  
Box 280  
Lanigan SK S0K 2M0

Attention Waterworks Owner/Operator:

**RE: Precautionary Drinking Water Advisory for *Town of Lanigan (Munster Street 22 – 63 only)* - Rescinded**

The Water Security Agency (WSA) is satisfied with the two sets of negative bacteriological sampling and adequate disinfection residuals and turbidity values from samples that have been collected from the water distribution system following the recent waterworks system depressurization. Therefore, effective immediately the WSA is rescinding the **“Precautionary Drinking Water Advisory”** for the residents and users of the Town of Lanigan water supply, in the area mentioned above, that was issued on July 14, 2025.

For further information, please do not hesitate to contact the undersigned at (306) 230-3254 or [lee.reinhart@wsask.ca](mailto:lee.reinhart@wsask.ca).

Sincerely,

A handwritten signature in black ink, appearing to read "Lee Reinhart".

WATER SECURITY AGENCY  
Lee Reinhart  
Supervisor, Environment Officer

cc: Brandy Boha, Environment Officer, Watrous Region, WSA  
Water Advisories, Water Security Agency  
Saskatchewan Health Authority, Yorkton Office